



Watertown Fire Department

OFFICE of FIRE CHIEF

106 Jones Street • Watertown, WI 53094 • Phone: (920) 261-3610

November 2, 2004

Mr. Tom Springer
W7932 Provimi Road
Watertown, WI 53098

Dear Mr. Springer,

This letter is to confirm the conversation we had this morning regarding temporary storage of shredded tire material on the west side of your business.

It is my recommendation that you construct a temporary concrete storage area of the following dimensions:

Walls not to exceed eight, (8), feet high, one hundred, (100), feet long, and sixty-five, (65), feet wide located at least fifty, (50), feet away from the western wall of your main building and at least fifty, (50), feet from the southern wall of the existing pole building.

Further it is my recommendation that by November 30, 2004 you begin removal of the existing pile of material that is west of the main building starting with the portion that is closest to the main building.

Sincerely,

Henry L. Butts
Fire Chief
Watertown Fire Department